# Barrier Management Symposium

Nestor Sanchez, USG Corporation


# Learning Objectives

- 1. Explore the gypsum mineral and its impact on fire resistance in a systems basis
- 2. Understand the different types of gypsum core and their relation to fire resistance
- 3. Construction details & repair methods for gypsum panels
- 4. Innovative Technology


## Fire Containment – Compartmentalize




- Calcium Sulfate
- CaSO<sub>4</sub>·2H<sub>2</sub>O
- 20% water by weight




• ASTM E 119 2hr. 1850 °F




1" back 950° F



2" back 220° F



4" back 180° F



6" back 130° F

## Hose Stream Test - Exposed Side



# Cold-Formed Steel Background




33 Mils=20ga

43 Mils=18ga


54 Mils=16ga



C-STUD / JOIST S-SECTIONS



TRACK
T-SECTIONS



CHANNEL U-SECTIONS





FURRING CHANNEL
F-SECTIONS

68 Mils=14ga

97 Mils=12ga

# 1 to 4 Hour Ratings






# Gypsum Core Types


Three (3) Types of Gypsum Cores


- Regular Core
- Type X
- Type C

# Panel Strength Comparison

- Simple Test @ 1850° F
- 13" x 13" x 5/8" Panels
- Regular, Type X & Type C Panels
- 12lb 9oz. loading







# Significance of Test

Type X core ≠ Type C core

Specify board type per UL design

Specified panel must be installed

# Floor-Ceiling Prior to Test



### GA-605 – Gyp. Panel Products for use in UL Classified Systems

- Free to download
- www.gypsum.org
- Gyp. Mfg. UL Type
   & Product Name



#### GYPSUM ASSOCIATION

USZC Elektrest Road, Suite 400, Hvattishille MD 20702

#### PROPRIETARY GYPSUM PANEL PRODUCTS FOR USE IN UL CLASSIFIED SYSTEMS

(GA-605)

The Fire Resistance Directory published by Underwriters Laboratories Inc. lists gypsum panel products that are classified for fire resistance under category "Gypsum Board (CKNNX)." Each UL Design lists the specific manufacturers and products that are suitable for use in the design. The products are identified with a Type designation that ties back to specific board formulations. The UL Type designation appears on the UL label on the product. However, gypsum board end tapes and product literature do not generally contain the UL type designation but a product name or trademark. The following tables provide a quick and easy reference to identify the specific products, brand names, or trademarks of each gypsum board manufacturer for each type designation in the UL Directory.

COMPANY NAME	PAGI
American Gypsum	1
CertainTeed Gypsum, Inc./CertainTeed Canada Inc.	2
Georgia-Pacific Gypsum	3
Lafarge North America	3
National Gypsum Company	4
PABCO Gypsum	4
Temple-Inland	5
United States Gynsum Company/CGC Inc	6

American Gypsum Company		
UL Type Designation	Product Name	
AG-C	1/2" FireBloc® Type C 5/8" FireBloc® Type C 5/8" FireBloc® Type C Soffit 1/2" M-Bloc® Type C with Mold Resistance 5/8" M-Bloc® Type C with Mold Resistance	
AGX-1, AGX-11	5/8" FireBloc® Type X 5/8" AquaBloc® Type X 5/8" Setterior Sheathing Type X 5/8" Soffit Type X 5/8" Soffit Type X 5/8" Veneer Type X 5/8" SmoothRoc® Type X 5/8" M-Bloc® Type X with Mold Resistance 5/8" M-Bloc® AR Type X Abuse and Mold Resistance 5/8" M-Bloc® Type X Impact and Mold Resistance	
AG-S	1" Shaft Liner 1" M-Bloc <sup>®</sup> Shaft Liner with Mold Resistance	
AG-CP	1/2" FireBloc® CP Gypsum Lay-In Ceiling Panels	

### GA-605 Type "C": Ex. Mfg. Name & UL Type

- American Gypsum: AG-C
- CertainTeed: ProRoc Type C
- GP: Type 5
- LaFarge: Type LGFC-C/A
- National Gypsum: Type FSW-C
- Pabco: Type PG-C & Type C
- Temple-Inland: Fire Rated Type TG-C
- USG: Type C
  - \* not all mfg.'s "C" core panels listed. See mfg.

### GA-605 Type "X": Ex. Mfg. Name & UL Type

- American Gypsum: Type AGX-1, AGX-11
- CertainTeed: ProRoc Type X
- GP: Type 9
- LaFarge: Type LGFC6A
- National Gypsum: Type FSW
- Pabco: Type PG-11
- Temple-Inland: Fire Rated Type X
- USG: Type SCX
  - \* not all mfg.'s "X" core panels listed. See mfg.

### INSTALLATION OF 1 HR WALL



**Horizontal Applied 1 HR U419.avi** 

### INSTALLATION OF 2 HR WALL



### Orientation of Gypsum Panels on Walls

Perpendicular to the studs (horizontally applied)

Parallel to the studs (vertically applied)

### Orientation of Gypsum Panels on Walls

- Conventional studs (minimum 25 gauge)
- Light gauge studs (equivalent thickness)

### Orientation of Gypsum Panels on Walls

### On Conventional Studs

- Vertical application Standard
- Horizontal application Referenced in the IBC and GA 600 Based on an old test
- Achieved by most wallboard manufacturers at UL


### Orientation of Gypsum Panels

### On Light Gauge Studs

- Vertical application Standard Most manufacturers
- Horizontal application Only achieved at UL with certain manufacturers

#### Fire Performance

Light Gauge Steel Stud Construction – UL U419




- Perpendicular (horizontal) installation with aligned horizontal joints
  - Top-down construction


1-hr Rated System Horizontal Without Backing

# Repair Gypsum Panels


- Incidental Tears
- Small Indentation
- Fractured Core
- "Crease in Panel"
- Back Paper Damage

# Repair Small Holes







# Repair Large Holes




### FLUSH PATCH - SMALL




### FLUSH PATCH - SMALL




INSTALLATION DETAILS







#### PARTIAL ELEVATION - 1




#### PARTIAL ELEVATION - 2





PARTIAL ELEVATION - 3

### SHAFTWALL PANEL REPLACEMENT



**Click** for Animation

### Innovations

- Mold Resistant Boards
- Lightweight Gypsum Panels Regular Core
- Lightweight Gypsum Panels
- Dust Control Joint Compound

### Resources

- U.L. Fire Resistance Directory
- Gypsum Association
- Manufacturers' Catalogs
- Technical Websites
  - UL Ultimate Fire Wizard
  - GA Association gypsum.org
  - Steel Framing Alliance steelframing.org

# Barrier Management Symposium

Nestor Sanchez, USG Corporation